



# TEST REPORT

**MANUFACTURER** : Tiinlab Acoustic Technology Limited

**PRODUCT NAME** : 1MORE ComfoBuds True Wireless Headphones

**MODEL NAME** : ESS3001T

**BRAND NAME** : 1MORE

**STANDARD(S)** : EN 50332-2:2013

**RECEIPT DATE** : 2020-05-26

**TEST DATE** : 2020-05-27

**ISSUE DATE** : 2020-09-25

Edited by: Wang Zhaoying  
Wang Zhaoying (Rapporteur)

Approved by: Li Dong  
Li Dong (Supervisor)

**NOTE:** This document is issued by MORLAB, the test report shall not be reproduced except in full without prior written permission of the company. The test results apply only to the particular sample(s) tested and to the specific tests carried out which is available on request for validation and information confirmed at our website.





# DIRECTORY

- 1. Technical Information..... 3**
- 1.1. Equipment under Test (EUT) Description..... 3**
- 1.2. Applied standards..... 4**
- 1.3. EUT Setup and Operating Conditions..... 4**
- 2. Measurement Method..... 5**
- 3. Test equipment..... 6**
- 4. Test Results..... 7**
- Annex A Photographs of the EUT..... 8**
- Annex B General Information..... 9**

<b>Change History</b>		
<b>Version</b>	<b>Date</b>	<b>Reason for change</b>
1.0	2020-09-25	First edition



# 1. Technical Information

**Note:** Provide by manufacturer.

## 1.1. Equipment under Test (EUT) Description

<b>EUT Type:</b>	1MORE ComfoBuds True Wireless Headphones
<b>Model No:</b>	ESS3001T
<b>Hardware Version:</b>	GT32-v2.1
<b>Software Version:</b>	V6.3
<b>Manufacturer:</b>	Tiinlab Acoustic Technology Limited
<b>Manufacturer Address:</b>	Tianliao Building 1403, Zone A Tianliao Industrial Park, Taoyuan Str., Nanshan Dist., Shenzhen, P.R. China

Note: This test report is variant from the original report (Report No.: SZ20050244A02, Model: ESS3001T), based on the similarity between before, made the following changes:

- 1.Add a grounded FPC in the headset.
- 2.Modification of the placement of inductors and capacitors.
- 3.Adjustment of test point position; adjustment of capacitor position.
- 4.Modify the Software and hardware version number.

In addition to the hardware differences described above, their electrical circuit design, layout, components used and internal wiring are identical, the others are the same as before, all test items are no need to be retested.

For a more detailed description, please refer to specification or user's manual supplied by the applicant and/or manufacturer.



## 1.2. Applied standards

According to the specifications of the manufacturer, the EUT must comply with the requirements of EN 50332-2.

Note 1: All test items were verified and recorded according to the standards and without any deviation during the test.

Note 2: When the test result is a critical value, we will use the measurement uncertainty give the judgment result based on the 95% risk level.

## 1.3. EUT Setup and Operating Conditions

During the measurement, the environmental conditions were within the listed ranges:

Temperature (°C):	15 - 35
Relative Humidity (%):	30 - 60
Atmospheric Pressure (kPa):	86 - 106



## 2. Measurement Method

This test method is based on the use of a Head and Torso Simulator(HATS), B&K type 4128 equipped with ear simulators type 4158 and 4159 in accordance with IEC 60318-7.

Test source signal used to measure the maximum sound pressure level is a program simulation noise, as defined in HD 483.1 S2., and its crest factor range is between 1.8~2.2. It is fed into the system simulator over the air to the device under test.

The sound pressure level measured by the ear simulator microphone represents the pressure found at eardrum level, and that levels have been correlated by the acoustic free-filled transfer function of the simulator. The results are given as free filed related A-weighted and in dB unit.

Test is repeated five times for each ear, and the earphones are removed and re-positioned each test prior to each measurement. The equipment under test is set in maximum volume value.

The maximum sound pressure level considered as the test result is the mean value of all  $L_{Aeq}$  measurements. Results shall not deliver more than 100dB for maximum SPL for player with headset/earphone.

Player output voltage of the “warning” appears, The maximum sound pressure level considered as the test result is the mean value of all  $L_{Aeq}$  measurements. Results shall not deliver more than 85dB for maximum SPL for player with headset/earphone.

For headset/earphone, the simulated programme signal characteristic voltage of analogue headphone input is the input signal voltage when the sound pressure level reaches 94 dB SPL A-weighted, and test procedure (same procedure above for player) is repeated five times. Results shall not be less than 75mV.

For the maximum output voltage measurement, the mV shall be defined as unweighted true r.m.s. voltage at the load, using and averaging time of 30s or more. Player output shall be loaded with a resistive load of 32  $\Omega$ . results shall not deliver more than 150mV.



### 3. Test equipment

Manufacturer	Name of equipment	Type/Model	Calibration Date	Due Date
B&K	HATS	4128-C-001	2019-06-25	2020-06-24
B&K	Conditioning Amplifier	2690-OS2	2019-06-20	2020-06-19
R&S	Audio Analyzer	UPV	2019-06-21	2020-06-20

The calibrated as a whole system is calibrated by the acoustical calibrator, and considers cable connections for accuracy, before starting test.

Uncertainty: Combined Uncertainty =1.22dB, based on 95% confidence level (K=2).



## 4. Test Results

Table 1 Player Maximum SPL

Channel	EN 50332-2(SPL dB(A))					P
	1st	2nd	3rd	4th	5th	Average value
Right Ear	98.59	98.23	98.20	98.30	98.55	98.37
Left Ear	96.72	97.10	97.15	97.95	97.17	97.34

Note: Results shall not deliver more than 100dB(A) for maximum SPL

### Conclusion

According to the test result and limits, the product was fulfilled the requirement of standard: EN62368-1:2014+A11:2017, EN60950-1: 2006+A1:2009 + A11:2011+A2: 2013(Zx. Protection against excessive sound pressure from personal music players).

## Annex A Photographs of the EUT

1



2







## Annex B General Information

### B.1 Identification of the Responsible Testing Laboratory

Laboratory Name:	Shenzhen Morlab Communications Technology Co., Ltd.
Laboratory Address:	FL.1-3, Building A, FeiYang Science Park, No.8 LongChang Road, Block 67, BaoAn District, ShenZhen, GuangDong Province, P. R. China
Telephone:	+86 755 36698555
Facsimile:	+86 755 36698525

### B.2 Identification of the Responsible Testing Location

Name:	Shenzhen Morlab Communications Technology Co., Ltd. Morlab Laboratory
Address:	FL.1-3, Building A, FeiYang Science Park, No.8 LongChang Road, Block 67, BaoAn District, ShenZhen, GuangDong Province, P. R. China

————— END OF REPORT —————